



OUTER DOOR SIGNS

BEAM IMMINENT
MUON BEAM ON
RF ON
RF ON TEST
SC MAG ON
NO ENTRY CONTROLLED ENTRY
SEARCHING
FREE ACCESS

AUX DOOR SIGNS

NO ENTRY FREE ACCESS
MUON BEAM ON RF ON
SC MAG ON

MICE HALL FIRE DOOR SIGNS (OVER LINAC)

NO ENTRY	MUON BEAM ON
FREE ACCESS	RF ON
SC MAG ON	

MICE HALL FIRE DOOR SIGNS (OVER LINAC)

SIGN DETAILS
 SIGN BOX - DARSBURY DRG 47/7522
 RED LED CLUSTER - MARL 084-501-22-98
 YELLOW LED CLUSTER - MARL 084-521-22-98
 GREEN LED CLUSTER - MARL 084-532-22-98

MSS	MICE HALL SEARCH SOUNDERS
MH	MICE HALL SIGNS TEST KEYS
STK	

- NOTES
- ENCLOSURE & TRUNKING LIDS TO BE PAINTED PPS ORANGE (RAL 2000)
 - FIT 230V AC WARNING LABELS AS REQUIRED
 - BOB SIGNS LOCATED ABOVE BOBS SEE SH# 2

MICE HALL SIGNS

SCALE 1:50

ALL DIMENSIONS IN MILLIMETERS UNLESS OTHERWISE STATED		
DRN	PAW	SCIENCE AND TECHNOLOGY FACILITIES COUNCIL
DATE	SEPT 2007	DARSBURY LABORATORY
CNO	PJW	OBSHIRE
DATE	AUG 08	
CERT		
MICE PERSONNEL PROTECTION SYSTEM LAYOUT OF EQUIPMENT		
DRG No	AO-204/75001	SH# 4
DATE	AUG 2007	ISSUE
DATE	DEC 2007	B
DRAWING LIST: - DL 204/75000		
CONTRACTORS COMPANY		

REV B FOR COMMENTS